

Puriton Service guidance – Connection to Copper pipe

25mm/32mm Puriton Type A service pipes and 22mm or 28mm copper pipe.

There is no direct solution jointing, however, it is possible to use the following method for connection to our Puriton Type A barrier pipe system.

Example below: -

Puriton mechanical fitting XR5240 – 25mm x 3/4" BSP female Puriton adaptor to 3/4" Male BSP x 22mm pipe.



A screwed connection is made at the $\frac{3}{4}$ " ends of each fitting. The brass fitting should be available from most Plumbers merchants.

Please ensure fittings used with Puriton fittings are suitable for drinking water and have the appropriate level of dezincification resistance, that the Water Authority Inspector will accept. All screwed connections should be completed using a suitable WRAS approved thread tape.

The image of the brass compression fittings is solely to demonstrate the method of connection between the materials, it is not manufacturer specific, the brass fitting should be available from most Plumbers merchants and must be an approved material of the adopting water authority.

Please see our latest Puriton pipe brochure for our extended range of adaptor fittings to facilitate Puriton service pipe connections.

Document end November 2021